

Dated. 25/03/2026

No. 02

It is certified that an inspection team headed by VIKAS VERMA, Assistant Engineer from U.P. Jal Nigam (Rural), HATHRAS, inspected the GLORY MODERN SCHOOL, SAHPAU, HATHRAS on 23/3/2026 and on the basis of Water Test Report bearing no UP/N/WR/1855/10/2026 dated 25/03/2026 of Regional Level Water Analysis Laboratory (UP JAL NIGAM) certified that the GLORY MODERN SCHOOL, SAHPAU, HATHRAS has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year from issue date

Signature with Seal:

Name VIKAS VERMA

Designation AE

Name & Address of the Office / Department

Regional Level Water Analysis Laboratory

विकास वर्मा
सहायक अभियन्ता
मुख्य कार्यालय
उत्तर प्रदेश जल निगम (ग्रामीण)
हथरस

To

GLORY MODERN SCHOOL,
SAHPAU, HATHRAS,

Water Analysis Report



District Level Water Analysis Laboratory U.P. Jal Nigam (Rural)

Address: Raya Road Sadabad, Hathras U.P. 281306

Email Id: eepjnrhathras@gmail.com

TelephoneNo-09473942536

Water Test Report

Report No:	UPIN/HAT/1855/Pvt./School/2026	Issue Date:	25.03.2026	Page No.1
------------	--------------------------------	-------------	------------	-----------

Customer Details

Office Name and Address	Glory Modern School, Sehpau Hathras
Ref. Letter No. & Date	GMS/2025-26/March/1403/23.03.2026

Basic Details of Sample

District	Hathras	Block/Tahseel	Sehpau
Gram Panchayat/Town	Sehpau	Village	Nagla Bihari
Habitation	Nagla Bihari	Location	Nagla Bihari Road Sepahu
Water Source	Submersible	Sample Code	HAT/1855
Quantity of Sample	1 litre	Sampling date	23-03-2026
Sample Received Date	23-03-2026	S. collected by	Manish Kumar
Sampling Method Used	As per IS17614:Part-I 2021	Sample Depositor	Rohit kumar
Analysis-Start Date	24-03-2026	Analysis Completion date:	24-03-2026
Temperature	25±3°C (25.8°C)	Humidity %	50±15% (57%)

S. No.	Analysed Parameters(Unit of Measuremet)	Observed Value	Specification as per IS 10500:2012(SecondRevision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023 (Qualitative Method)
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018 (Qualitative Method)
3	pH (at 25°C)	7.47	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022. (Electrometric Method)
4	Colour (Hazen units)	1	5	15	IS 3025 (Part 4): 2021 (Visual Comparison Method)
5	Turbidity (NTU)	2.05	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
6	Total Dissolved Solids, (at 180°C) Mg/l	1078	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
7	Chloride (as Cl), mg/l	80	250	1000	IS 3025 (Part 32): 2025 Argentometric method
8	Total Alkalinity, (as CaCO ₃) mg/l	515	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
9	Total Hardness, (as CaCO ₃) mg/l	205	200	600	IS 3025 (Part 21): 2023 (EDTA method)
10	Calcium (as Ca), mg/l	16.03	75	200	IS 3025 (Part 40): 2024 EDTA Titrimetric method
11	Sulphate (as SO ₄), mg/l	47.72	200	400	APHA 24rd Edition -4500-SO ₄ Method E (Turbidimetric Method): 2023
12	Nitrate (as NO ₃), mg/l	21.80	45	45	APHA 24rd Edition -4500- NO ₃ (Method B UV Screening method): 2023
13	Iron (as Fe), mg/l	0.31	1.0	1.0	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method): 2023
14	Fluoride (as F), mg/l	1.11	1.0	1.5	APHA 24rd Edition -4500-F Method C (Electrode Method): 2023
15	Magnesium (as Mg) mg/l	40.09	30	100	IS 3025 (Part 46): 2023 (Volumetric method)

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.

2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.


3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.

4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.

5. Parameters above Permissible Limit are written in bold.

6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available

7. Sample is not Collected by Lab.


Munendra Kumar
 (Report prepared by)



waterdistrictlab@gmail.com

*****END OF THE ANALYSIS REPORT*****